


Steel Weld Tee

USE: To make a lateral pipe connection



Purchase Description and Passport P-Comments

TEE, carbon steel, per ASTM A234 grade WPB, weld end _____
 (run)

_____ x _____, per ANSI B 16.9.
 (wall thickness) (branch) (wall thickness)

Current editions incorporated by reference in Title 49 CFR part 192.

Catalog ID	Nom. Pipe Size (in)		Run		Branch		Approx. Weight (lb)	Schedule
	(AB)	(C)	Outside Dia. (in)	Wall Thickness (in)	Outside Dia. (in)	Wall Thickness (in)		
59535	1/2	1/2	0.840	.0109	0.840	0.109	0.30	40
59539	3/4	3/4	1.050	0.113	1.050	0.113	0.42	40
59727	1	3/4	1.315	0.179	1.050	0.154	0.95	80
59545	1	1	1.315	0.133	1.315	0.133	0.85	40
59723	1	1	1.315	0.179	1.315	0.179	0.97	80
59556	1-1/4	3/4	1.660	0.140	1.050	0.113	1.51	40
59552	1-1/4	1-1/4	1.660	0.140	1.660	0.140	1.55	40
59562	1-1/2	1-1/2	1.900	0.145	1.900	0.145	1.70	40
59579	2	3/4	2.375	0.154	1.050	0.113	2.30	40
59580	2	1	2.375	0.154	1.315	0.133	2.33	40
59581	2	1-1/4	2.375	0.154	1.660	0.140	2.77	40
111741	2	2	2.375	0.154	2.375	0.154	3.26	40
59586	2-1/2	2-1/2	2.875	0.203	2.875	0.203	5.21	40
59607	3	1	3.500	0.216	1.315	0.133	6.00	40
59608	3	1-1/4	3.500	0.216	1.660	0.140	6.25	40
59609	3	2	3.500	0.216	2.375	0.154	7.50	40
111743	3	3	3.500	0.216	3.500	0.216	7.60	40
59628	4	2	4.500	0.237	2.375	0.154	10.20	40
111745	4	3	4.500	0.237	3.500	0.216	11.00	40
59617	4	4	4.500	0.237	4.500	0.237	12.2	40
59648	6	3	6.625	0.280	3.500	0.216	32	40
59503	6	4	6.625	0.219	4.500	0.188	30	---
59649	6	4	6.625	0.280	4.500	0.237	33	40
59499	6	6	6.625	0.219	6.625	0.219	31	---
59640	6	6	6.625	0.280	6.625	0.280	34	40